The following are questions submitted by prospective bidders for the Interior Clean-Out and Possible Asbestos Flooring Abatement at 64 East Main Street Project:

1. **Question:** Is water and electric available on site? Are working outlets and a hose bib connection available?

   Response: No, No

2. **Question:** Are we responsible for any MEP demo?

   Response: No, the project is for clean-out and not demolition

3. **Question:** Who is responsible to disconnect all MEP prior to demolition?

   Response: The chosen contractor prior to clean-out

4. **Question:** Please provide a drawing of structural walls that are to remain?

   Response: All structural walls are to remain

5. **Question:** What doors are to remain?

   Response: Exterior entry and exit doors are to remain

6. **Question:** Are hard ceilings, like drywall or plaster to be demolished?

   Response: No

7. **Question:** Is a site fence required?

   Response: No

8. **Question:** Are there any fees associated with permits or will any fees be waived?

   Response: No fees associated with permits

9. **Question:** Is a bid bond required?

   Response: No, since the cleanout project is not expected to exceed $100k

10. **Question:** Is this a subchapter 8 project for asbestos? If yes, is the space occupied or unoccupied?

    Response: Yes, the space is unoccupied.

11. **Question:** The asbestos floor tile removal is only listed for certain areas. Should we assume the asbestos floor tile is throughout the entire building?

    Response: Yes

12. **Question:** Are non-asbestos flooring materials to be removed (ex. ceramic flooring, carpet, VCT, sheet vinyl, T/G wood flooring, etc.)

    Response: Yes

13. **Question:** Is this a prevailing wage project?

    Response: Yes